



		A	
HES	SMALL PLANET SUPPLY TUMWATER, WA		
•.	TITLE:		
).	DROPLET3		
	SUBMITTAL (MOUNTING REQUIREMENTS)		
Y PER ANCHOR PER ANCHOR	SIZE DWG. NO. 003-0008	REV A	
	SCALE: 1:10 SHE	ET 2 OF 4	
	2		

## PERFORMANCE

4

HEATING CAPACITY (ABOVE 5°F) [BTUH]	46,200
NOMINAL OUTPUT [GPM @ 100°F LIFT]	0.92
MAX. DAILY OUTPUT [GAL./DAY @ 100°F LIFT]	887
MAX. DAILY RUNTIME [HOURS / DAY]	16
AIRFLOW [CFM]	1,800
EXTERNAL STATIC PRESSURE [INH2O]	0
SOUND LEVEL [dB(A)]	40
*MAX. PIPE LENGTH TO STORAGE TANKS [FT.]	55
*MAX. VERTICAL DISTANCE TO STORAGE TANK [FT.]	20
REFRIGERANT TYPE	R-744
TOTAL CHARGE [OZ.]	76.2
MAX. SYSTEM WATER PRESSURE [PSI]	75
HEAT TRACE CAPACITY [W/FT.] (OPTIONAL)	8

\*LIMITED BY HEAT PUMP INTERNAL CIRCULATOR PUMP AVAILABLE HEAD

### **ELECTRICAL**

VOLTAGE/PHASE/FREQ.	208V/1Ø/60Hz	
FLA [A]	37.7	
MCA [A]	54.4	
MOCP [A]	60	

#### <u>WEIGHT</u>

4

DRY WEIGHT, INSTALLED* [LBS.]	850	

#### \*APPROX.

COMPONENT & CONSTRUCTION DETAIL			
	20-MESH WYE-STRAINER LOCATED ON COLD S		
	INDIVIDUAL HEAT PUMP ISOLATION AND CHEC		
	HEAT TRACE ON PIPNG AND CONDENSATE DR		
	PAINTED STEEL FRAME		
	1-1/2" PIPE INSULATION		
	TYPE K COPPER PIPING		

ONBOARD STAGING CONTROLLER

UL508A PANEL

#### MOUNTING ANCHORS

DIAMETER	1/2"
UPLIFT/PULLOUT CAPACITY [lbf]	1,000
SHEAR CAPACITY [lbf]	750
NO. OF ANCHORS REQUIRED	4

# FIELD CONNECTIONS

<u>ELECTRICAL</u>	LINE	
	NEUTRAL	
	GROUND	
<u>Plumbing</u>	HOT WATER OUTLET	3/4" ( S
	COLD WATER SUPPLY	1" COF
	CONDENSATE DRAIN	1/2'' P RESI

2

3

Α

2

## SUPPLY

# CK VALVES

# RAIN PANS (OPTIONAL)





